

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND
SANITARY CONDITION CERTIFICATE.

No..116

Date - 10/04/2026

It is certified that an inspection team headed by Jitendra Kumar Tarendra Sub Engineer (Name of Officers with designation) from Public Health Engg. Department (NABL LAB) Bijapur (Name of Department/Office) inspected the Eklavya Model Residential School - BIJAPUR, Block - Bijapur, District Bijapur (C.G.), (Name & Address of the School) on 10.04.2026 and found that the Eklavya Model Residential School - BIJAPUR Block - Bijapur, District Bijapur (C.G.), (Name of School) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the central/State/U.T. Govt.

The above valid for a period of 10.04.2027


Signature with Seal :-

Name : - Jitendra Kumar Tarendra

Designation :- Sub Engineer P.H.E. Bijapur

Dist. - Bijapur (C.G.)

To

**The Principal
Eklavya Model Residential
School - Bijapur
District Bijapur (C.G.)
Pin code - 494444**



District Water Testing Laboratory

Public Health Engineering Division Bijapur Chhattisgarh

Jaitaloor Road Ambedkar Ward, PIN-494444

Email- eebij-phe-cg@nic.in

Test Report

Format Id- DWTL/PHED/BJP/F/8

Certificat No. TC- 16009	ULR No: TC16009260000116F		Sample Collected by - Debabrota Thekdev	
Sender's Name and Address: A.E. PHED Sub. Division Bijapur	Sender's letter no.	116	Sender's letter Date	10.04.2026
	DL Receipt No.	116	DL Received date	10.04.2026
	Date of analysis started	10.04.2026	Date of analysis completed	13.04.2026

Sample Details-

Sr. No.	Block & District	Village & Panchayat	Sample ID	Condition of Sample	Location/Source No.
1	Bijapur	Bijapur	1055	OK	EMRS School Education City Bijapur
2	Bijapur	Bijapur	1056	OK	EMRS Boys Hostal Education City Bijapur
3	Bijapur	Bijapur	1057	OK	EMRS Girls Hostal Education City Bijapur

sender's Name and Address: A.E. PHE Sub Division Bijapur

Sr. No.	Characteristics	Test method IS:3025 & APHA	Unit of Measurement	As Per BIS -10500:2012 For Drinking Water		Results			
				Acceptable Limit	Permissible Limit	1	2	3	4
1	2	3	4	5	6				
				Sample ID -->		1055	1056	1057	
1	Turbidity	IS:3025 Part -10: 2023	NTU	1.0	5.0	0.8	0.6	0.3	
2	pH @ 25°C	IS:3025 Part -11: 2022	pH scale	6.5 - 8.5	6.5 -8.5	7.1	6.7	6.8	
3	Colour	IS:3025Part - 4: 1983 RA 2017	Hazen	5	15	5	5	5	
4	Taste	IS:3025 Part - 8: 2023	-	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable	
5	Odour	IS:3025 Part - 5: 2018 RA 2022	-	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable	
6	Total Hardness as CaCO ₃	IS:3025 Part - 21: 2009 RA 2023	mg/l	200	600	124.44	106.08	93.84	
7	Calcium as Ca ⁺⁺	IS:3025 Part - 40: 2024	mg/l	75	200	65.41	33.52	9.81	
8	Magnesium as Mg ⁺⁺	APHA 3500 24th Edition Part -MgB 2023	mg/l	30	100	9.41	5.45	16.85	
9	Total Dissolved Solid	IS:3025 Part - 16: 2023	mg/l	500	2000	200	170	150	
10	Total Alkalinity as CaCO ₃	IS:3025 Part - 23: 2023	mg/l	200	600	78.8	104.41	65.01	
11	Chloride as Cl ⁻	IS:3025 Part - 32: 1988 RA 2019	mg/l	250	1000	49.95	43.95	46.95	

- 1 This report should not be produced partly or full without approval of signatory authority of legal purposes
- 2 It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source" in column 7 above which the sources will have to be rejected.
- 3 **The results refer only to tested samples and parameters tested.**
- 4 Samples will be stored for a period of 10 days from the date of issue of report.
- 5 This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.
- 6 **The Laboratory does not give interpretation on Test result PASSED / FAILED**
- 7
 1. Results apply to the sample as received
 2. Sampling not done by the Laboratory Staff

Sapna Mandal
Chemist

Authorised Signatory (NABL)

Issue No.116/Lab./ Date-13.04.2026

**District Water Testing Laboratory
Public Health Engineering Division Bijapur Chhattisgarh**

Jaitaloor Road Ambedkar Ward, PIN-494444

Email- eebij-phe-cg@nic.in

Test Report

Format Id- DWTL/PHED/BJP/F/8

		Sample Collected by - Debabrota Thekdev	
Sender's Name and Address: A.E. PHED Sub. Division Bijapur	Sender's letter no.		Sender's letter Date
	DL Receipt No.		DL Received date 10.04.2026
	Date of analysis started	10.04.2026	Date of analysis completed 13.04.2026

Sample Details-

Sr.No.	Block & District	Village & Panchayat	Sample ID	Condition of Sample	Location/Source No.
1	Bijapur	Bijapur	1055	OK	EMRS School Education City Bijapur
2	Bijapur	Bijapur	1056	OK	EMRS Boys Hostal Education City Bijapur
3	Bijapur	Bijapur	1057	OK	EMRS Girls Hostal Education City Bijapur

sender's Name and Address: A.E. PHE Sub Division Bijapur

Sr No	Characteristics	Test method IS:3025 & APHA	Unit of Measurement	As Per BIS -10500:2012 For Drinking Water		Results			
				Acceptable Limit	Permissible Limit	1	2	3	4
				5	6				
				Sample ID -->		1055	1056	1057	
1	Iron	IS:3025 Part -3500-Fe-	mg/l	1.0	1.0	0.2	0.1	0.2	
2	Fluoride	IS:3025 Part -4500-F-C	mg/l	1.0	1.5	0.1	0.1	0.2	
3	Total Coliform	APHA 24th Edition Part 9222 B	CFU/100ml	No Relaxation	No Relaxation	Nil	Nil	Nil	
4	E.Coli	APHA 24th Edition	CFU/100ml	No Relaxation	No Relaxation	Nil	Nil	Nil	

This report should not be produced partly or full without approval of signatory authority of legal purposes

It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source" in column 7 above which the sources will have to be rejected.

The results refer only to tested samples and parameters tested.

Samples will be stored for a period of 10 days from the date of issue of report.

This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.

The Laboratory does not give interpretation on Test result PASSED / FAILED

1. Results apply to the sample as received
2. Sampling not done by the Laboratory Staff



**Sapna Mandal
Chemist**

Authorised Signatory

Issue No.116/Lab./Date-13/04.2026

End of Report